



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J1E0475

Oxford Academy and Central School District

Project Name: Lead Testing

Mark Hodge
 50 South Washington Avenue
 Oxford, NY 13830

Project / PO Number: N/A
 Received: 04/28/2021
 Reported: 05/20/2021

Analytical Testing Parameters

Client Sample ID: 792409-P.S. 7	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:16
Lab Sample ID: J1E0475-01	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1222	LLW

Client Sample ID: 792364-P.S 8	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:14
Lab Sample ID: J1E0475-02	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1227	LLW

Client Sample ID: 792346-P.S 10	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:10
Lab Sample ID: J1E0475-03	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1229	LLW

Client Sample ID: 792405-P.S 12	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:08
Lab Sample ID: J1E0475-04	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1231	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792374-P.S 13	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:05
Lab Sample ID: J1E0475-05	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1233	LLW

Client Sample ID: 792417-P.S 15	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 6:56
Lab Sample ID: J1E0475-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1234	LLW

Client Sample ID: 792439-P.S 17	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:20
Lab Sample ID: J1E0475-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1240	LLW

Client Sample ID: 792422-P.S 18	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:22
Lab Sample ID: J1E0475-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1242	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792438-P.S 19	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:25
Lab Sample ID: J1E0475-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1244	LLW

Client Sample ID: 792456-P.S 20	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:27
Lab Sample ID: J1E0475-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1245	LLW

Client Sample ID: 792258-P.S 21	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:29
Lab Sample ID: J1E0475-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1247	LLW

Client Sample ID: 792436-P.S 23	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:32
Lab Sample ID: J1E0475-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1251	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792393-P.S 24	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:34
Lab Sample ID: J1E0475-13	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1253	LLW

Client Sample ID: 792434-P.S 25	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:37
Lab Sample ID: J1E0475-14	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1255	LLW

Client Sample ID: 792455-P.S 26	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:40
Lab Sample ID: J1E0475-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1256	LLW

Client Sample ID: 792380-P.S 27	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:42
Lab Sample ID: J1E0475-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1302	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792329-P.S 28	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:46
Lab Sample ID: J1E0475-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1304	LLW

Client Sample ID: 792365-P.S 29	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:48
Lab Sample ID: J1E0475-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1306	LLW

Client Sample ID: 792328-P.S 31	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:50
Lab Sample ID: J1E0475-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1307	LLW

Client Sample ID: 792390-P.S 32	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:52
Lab Sample ID: J1E0475-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1139	05/13/21 1309	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792442-P.S 33	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:54
Lab Sample ID: J1E0475-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1318	LLW

Client Sample ID: 792448-P.S 34	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:56
Lab Sample ID: J1E0475-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1324	LLW

Client Sample ID: 792370-P.S 35	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:58
Lab Sample ID: J1E0475-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1326	LLW

Client Sample ID: 792451-P.S 36	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 8:01
Lab Sample ID: J1E0475-24	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1327	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792413-P.S 37	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 8:04
Lab Sample ID: J1E0475-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1329	LLW

Client Sample ID: 792351-P.S 38	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 8:07
Lab Sample ID: J1E0475-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1331	LLW

Client Sample ID: 792366-P.S 39	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 8:10
Lab Sample ID: J1E0475-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1337	LLW

Client Sample ID: 792447-H.S 1	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:17
Lab Sample ID: J1E0475-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1338	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792418-H.S 2	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:12
Lab Sample ID: J1E0475-29	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1340	LLW

Client Sample ID: 792362-H.S 3	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:23
Lab Sample ID: J1E0475-30	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1342	LLW

Client Sample ID: 792343-H.S 44	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:10
Lab Sample ID: J1E0475-31	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1344	LLW

Client Sample ID: 792407-H.S 16	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:31
Lab Sample ID: J1E0475-32	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1348	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792396-H.S 41	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 8:10
Lab Sample ID: J1E0475-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1349	LLW

Client Sample ID: 792381-H.S 42	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 8:05
Lab Sample ID: J1E0475-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1351	LLW

Client Sample ID: 792445-M.S 1	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 6:48
Lab Sample ID: J1E0475-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1353	LLW

Client Sample ID: 792376-M.S 2 (Bottle marked 792437-M.S 1)	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 6:55
Lab Sample ID: J1E0475-36	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1359	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Client Sample ID: 792429-M.S 3	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:01
Lab Sample ID: J1E0475-37	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1400	LLW

Client Sample ID: 792367-M.S 4	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:09
Lab Sample ID: J1E0475-38	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1402	LLW

Client Sample ID: 792404-M.S 5	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 7:06
Lab Sample ID: J1E0475-39	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1404	LLW

Client Sample ID: 792409-P.S. 9	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 04/28/2021 9:15
Lab Sample ID: J1E0475-40	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		05/13/21 1213	05/13/21 1406	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E0475

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

Jennifer Walker

Operations Manager

Reported: 05/20/2021 22:15

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

CHAIN OF CUSTODY RECORD

MICROBAC 2592 Hope Mills Rd., Fayetteville, NC 28306 | 910.864.1920 p | 910.864.8774 f

Number
Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Temperature Upon Receipt (°C)
Therm ID

Routine (5 to 7 business days)
 RUSH* (notify lab)

Holding Time
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Invoice Address

Client Name:
Oxford Academy & Central Schools

Address:
50 South Washington Street
Oxford, NY 13830
Mark Hodge
Telephone No.: 607-843-2025 ext 1156

Lab Report Address

Client Name:
Oxford Academy & Central Schools

Address:
50 South Washington Street
Oxford, NY 13830
Mark Hodge
Telephone No.: 607-843-2025 ext 1156

Send Report via: Mail Fax e-mail (address)
Send Invoice via: Mail Fax e-mail (address)
Compliance Monitoring? Yes No
() Agency/Program

PO No.:
mhodge@oxac.org

Location:

Sampler Phone No.:

Sampler Signature:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved



Oxford Academy and Central School District
PM: Shannon Weeks

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Requested Analysis	Additional Info
792409-P.S. 7		4-28-21	7:16	1					
792364-P.S. 8		4-28-21	7:14	1					
792402-P.S. 9		N/A							
792346-P.S. 10		4-28-21	7:10	1					
792377-P.S. 11		N/A							
792405-P.S. 12		4-28-21	7:08	1					
792374-P.S. 13		4-28-21	7:05	1					
792417-P.S. 15		4-28-21	6:56	1					
792439-P.S. 17		4-28-21	7:20	1					
792422-P.S. 18		4-28-21	7:22	1					

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Disposal as appropriate Return Archive

Comments	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)
Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 Level 2 Level 3 Level 4

Turnaround Time

Routine (5 to 7 business days)
 RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via: Mail Fax e-mail (address)

Location:

PO No.:

Compliance Monitoring? Yes No
() Agency/Program

Lab Report Address

Client Name: Oxford Academy & Central Schools

Address: 50 South Washington Street

City, State, Zip: Oxford, NY 13830

Contact: Mark Hodge

Telephone No.: 607-843-2025 ext 1156

Send Report via: Mail Fax e-mail (address)

Project:

Sampler Phone No.:

Sampler Signature:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	* Preservative Types	Additional Notes
792438	P.S. 19	4/28/21	7:25	1				
792456	P.S. 20	4/28/21	7:27	1				
792258	P.S. 21	4/28/21	7:29	1				
792415	P.S. 22	N/A						
792436	P.S. 23	4/28/21	7:32	1				
792393	P.S. 24	4/28/21	7:34	1				
792434	P.S. 25	4/28/21	7:37	1				
792455	P.S. 26	4/28/21	7:40	1				
792380	P.S. 27	4/28/21	7:42	1				
792329	P.S. 28	4/28/21	7:46	1				

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Comments

Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time

CHAIN OF CUSTODY RECORD

MICROBAC® 2592 Hope Mills Rd., Fayetteville, NC 28306 | 910.864.1920 p | 910.864.3774 f

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address

Client Name: Oxford Academy & Central Schools
 Address: 50 South Washington Street
 City, State, Zip: Oxford, NY 13830
 Contact: Mark Hodge
 Telephone No.: 607-843-2025 ext 1156
 Send Report via: Mail Fax e-mail (address)

Invoice Address

Client Name: Oxford Academy & Central Schools
 Address: PO Box 192
 City, State, Zip: Oxford, NY 13830
 Contact: Hope Crawford
 Telephone No.: 607-843-2025 ext 4042
 Send Invoice via: Mail Fax e-mail (address)

Turnaround Time

Routine (5 to 7 business days)
 RUSH* (notify lab)

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type: Results Only Level 1 Level 2 Level 3 Level 4 EDD

Project: Location: PO No.: Compliance Monitoring? Yes No
 () Agency/Program

Sampled by (PRINT): Sampler Signature: Sampler Phone No.:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types *	Additional Notes
792365	P.S. 29	4-28-21	7:48	1				
792328	P.S. 31	4-28-21	7:50	1				
792390	P.S. 32	4-28-21	7:52	1				
792442	P.S. 33	4-28-21	7:54	1				
792448	P.S. 34	4-28-21	7:56	1				
792370	P.S. 35	4-28-21	7:58	1				
792451	P.S. 36	4-28-21	8:01	1				
792413	P.S. 37	4-28-21	8:04	1				
792351	P.S. 38	4-28-21	8:07	1				
792366	P.S. 39	4-28-21	8:10	1				

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)
Therm ID
Holding Time
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

MICROBAC 2592 Hope Mills Rd., Fayetteville, NC 28306 | 910.864.1920 p | 910.864.8774 f

Lab Report Address

Client Name: Oxford Academy & Central Schools
Address: 50 South Washington Street
City, State, Zip: Oxford, NY 13830
Contact: Mark Hodge
Telephone No.: 607-843-2025 ext 1156

Turnaround Time

Routine (5 to 7 business days)
 RUSH* (notify lab)

Client Name: Oxford Academy & Central Schools
Address: PO Box 192
City, State, Zip: Oxford, NY 13830
Contact: Hope Crawford
Telephone No.: 607-843-2025 ext 4042

Send Report via: Mail Fax e-mail (address) mhodge@oxac.org
Location: PO No.:
Project: Compliance Monitoring? Yes No
Agency/Program

Sampled by (PRINT):
Sampler Signature:
Sampler Phone No.:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Sample Disposition	Sample Disposition	Received By (signature)	Date/Time	Additional Notes
	792414-P.S. 40	N/A						<input type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive				
	792325-P.S. 43	N/A										
Possible Hazard Identification <input type="checkbox"/> Hazardous <input type="checkbox"/> Non-Hazardous <input type="checkbox"/> Radioactive												
Comments												

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)
Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No
() Agency/Program

PO No.:

Sampler Phone No.:

Location:

Sampler Signature:

Sampled by (PRINT):

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Sample Disposition	Received By (signature)	Date/Time	Additional Notes
0022503	792447 - H.S. 1	042821	7:17 AM	1							
0022503	792418 - H.S. 2	042821	7:12 AM	1							
0022503	792362 - H.S. 3	042821	7:23 AM	1	WATER						
	792450 - H.S. 4	N/A									
	792399 - H.S. 5	N/A									
0022503	792343 - H.S. 44	042821	7:10 AM	1							
0022503	792407 - H.S. 16	042821	7:31 AM	1							
	792396 - H.S. 41	042821	8:10 AM	1	DRINKING						
	792381 - H.S. 42	042821	8:05 AM	1							
Possible Hazard Identification: () Hazardous () Non-Hazardous () Radioactive () Dispose as appropriate () Return () Archive											
Comments: CONcession BLDG.											



CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Temperature Upon Receipt (°C)
Therm ID

Routine (5 to 7 business days)
 RUSH* (notify lab)

Holding Time

Level 1 Level 2 Level 3 Level 4 EDD

Samples Received on Ice? Yes No N/A

(needed by)

Custody Seals Intact? Yes No N/A

Report Type

Compliance Monitoring? Yes No

Mail Fax e-mail (address)

Agency/Program

Send Invoice via: mhodge@oxac.org

PO No.:

Sampler Phone No.:

Sampler Signature:

Location:

Matrix

Grab / Comp

No. of Containers

Preservative Types *

Time Collected

Date Collected

Client Sample ID

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature)

Received By (signature)

Relinquished By (signature)

Received By (signature)

Relinquished By (signature)

Received By (signature)

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time



MICROBAC 2592 Hope Mills Rd., Fayetteville, NC 28306 | 910.864.1920 p | 910.864.8774 f

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) **22.1**

Therm ID **014**

Holding Time

Samples Received on Ice? Yes No **N/A**

Custody Seals Intact? Yes No **N/A**

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

Invoice Address

Client Name: Oxford Academy & Central Schools

Address: PO Box 192

City, State, Zip: Oxford, NY 13830

Contact: Hope Crawford

Lab Report Address

Client Name: Oxford Academy & Central Schools

Address: 50 South Washington Street

City, State, Zip: Oxford, NY 13830

Contact: Mark Hodge

Send Report via:

Mail Fax e-mail (address)

Telephone No.: 607-843-2025 ext 1156

Send Invoice via: mhodge@oxac.org

607-843-2025 ext 4042

Project:

Location:

PO No.:

Compliance Monitoring? Yes No

() Agency/Program

Sampled by (PRINT):

Sampler Signature:

Sampler Phone No.:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	* Preservative Types	Additional Notes
	792427-M.S. 9							

Possible Hazard Identification	<input type="checkbox"/> Hazardous	<input type="checkbox"/> Non-Hazardous	<input type="checkbox"/> Radioactive	Sample Disposition	<input type="checkbox"/> Dispose as appropriate	<input type="checkbox"/> Return	<input type="checkbox"/> Archive
Comments							
				Received By (signature)		4/28/21	9:51
				Relinquished By (signature)			
				Received By (signature)			
				Relinquished By (signature)			
				Received By (signature)			