



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS
J4L0739

Oxford Academy and Central School District

Project Name: Oxford Schools - Middle School

Mark Hodge
 50 S Washington AVE
 Oxford, NY 13830

Project / PO Number: N/A
 Received: 12/17/2024
 Reported: 12/31/2024

Analytical Testing Parameters

Client Sample ID:	M.S Kitchen	Collected By:	Mark Hodge
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:38
Lab Sample ID:	J4L0739-01		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0042	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1327	JDF

Client Sample ID:	M.S Fountain Cafe	Collected By:	Mark Hodge
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:38
Lab Sample ID:	J4L0739-02		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1331	JDF

Client Sample ID:	M.S Home Ec	Collected By:	Mark Hodge
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:40
Lab Sample ID:	J4L0739-03		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1333	JDF

Client Sample ID:	M.S Nurse Office	Collected By:	Mark Hodge
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:50
Lab Sample ID:	J4L0739-04		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1334	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0739

Client Sample ID: M.S Fountain Nurse	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 12/17/2024 6:46
Lab Sample ID: J4L0739-05	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1336	JDF

Client Sample ID: M.S Fountain Guidance	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 12/17/2024 6:48
Lab Sample ID: J4L0739-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0066	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1338	JDF

Client Sample ID: M.S Fountain 224	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 12/17/2024 6:44
Lab Sample ID: J4L0739-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1342	JDF

Client Sample ID: M.S 5th Grade Fountain	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 12/17/2024 6:54
Lab Sample ID: J4L0739-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1344	JDF



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS
 J4L0739

Client Sample ID: M.S 6th Grade Fountain	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 12/17/2024 6:56
Lab Sample ID: J4L0739-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1345	JDF

Client Sample ID: M.S Fountain 324	Collected By: Mark Hodge
Sample Matrix: Drinking Water	Collection Date: 12/17/2024 6:58
Lab Sample ID: J4L0739-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		12/26/24 1253	12/26/24 1347	JDF

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)


Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.
 The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Shannon Weeks
 Customer Relationship Coordinator
 Reported: 12/31/2024 08:57



3821 Buck Dr.
Cortland, NY 13045
607.763.3403

2369 Elmira St., Suite C
Sayre, PA 18840
670.888.0169

428 Route 315 Hwy
Plittston, PA 18640
570.348.0775

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY MICROBAC
Temperature Upon Receipt (°C) 18.9°

Therm ID IR-1

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Lab Report Address

Client Name:

Oxford Schools

Address:

R Fort Hill Park

City, State, Zip:

Oxford, NY 13830

Contact:

Maech Hodore

Telephone No.:

607-843-2025 ext 156

Send Report via:

Mail Fax e-mail (address)

Invoice Address

Client Name:

Oxford Schools

Address:

P.O. Box 192

City, State, Zip:

Oxford NY 13830

Contact:

Hope Crawford

Telephone No.:

607-843-2025 ext 4042

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via:

Mail Fax e-mail (address)

Project:

MIDDLE SCHOOL

Location:

Water Dist.

PO No.:

Compliance Monitoring? Yes No

() Agency/Program

Sampled by (PRINT):

Maech Hodore

Sampler Signature:

Maech Hodore

Sampler Phone

No.:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

RLF 12/17/24

REQUESTED ANALYSIS

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types
000030	M.S. Kitchen	12/17/24	6:38	1			*
019249	M.S. Fountain Cafe	12/17/24	6:36	1			
019184	M.S. Home Ec	12/17/24	6:40	1			
019177	M.S. Nurse office	12/17/24	6:50	1			
019246	M.S. Fountain Nurse	12/17/24	6:46	1			
000007	M.S. Fountain Guidance	12/17/24	6:48	1			
000071	M.S. Fountain 224	12/17/24	6:44	1			
013783	M.S. 5 th Fountain	12/17/24	6:54	1			
A	M.S. 6 th Fountain	12/17/24	6:56	1	Drinking water		
B	M.S. Fountain 324	12/17/24	6:58	1	Drinking water		

LEAD (Pb)

Oxford Academy and Central School District
P.M. Shannon Weeks



Possible Hazard Identification

Hazardous Non-Hazardous Radioactive

Sample Disposition

Dispose as appropriate Return Archive

PLEASE SUBMIT PAYMENT WITH SAMPLES.

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

PLEASE RETURN SAMPLES ON ICE.

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

PLEASE BE SURE TO FILL THE CONTAINER(S) UP TO THE SHOULDER

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

* HNO3 ADDED TO EACH SAMPLE - J432022 - RLF 12/19/24