



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Oxford Academy and Central School District

Project Name: Lead Testing

Mark Hodge
50 South Washington Avenue
Oxford, NY 13830

Project / PO Number: A16-00991
Received: 04/08/2016 09:53
Reported: 04/20/2016 17:23

Analytical Testing Parameters

Client Sample ID: H.S. 1
Lab Sample ID: J6D0481-01
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00210, 0.00100, mg/L, 04/18/16 1509, 04/18/16 2004

Analytical Testing Parameters

Client Sample ID: H.S. 2
Lab Sample ID: J6D0481-02
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:01

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00180, 0.00100, mg/L, 04/18/16 1509, 04/18/16 2007

Analytical Testing Parameters

Client Sample ID: H.S. 3
Lab Sample ID: J6D0481-03
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:02

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1509, 04/18/16 2011



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: H.S. 4
Lab Sample ID: J6D0481-04
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:03

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1509, 04/18/16 2014

Analytical Testing Parameters

Client Sample ID: H.S. 5
Lab Sample ID: J6D0481-05
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:04

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2018

Analytical Testing Parameters

Client Sample ID: H.S. 44
Lab Sample ID: J6D0481-06
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:05

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2032



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: H.S. 16
Lab Sample ID: J6D0481-07
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:06

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, 0.00224, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2035

Analytical Testing Parameters

Client Sample ID: H.S. 6
Lab Sample ID: J6D0481-08
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:07

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2046

Analytical Testing Parameters

Client Sample ID: H.S. 41
Lab Sample ID: J6D0481-09
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:09

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2049



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 7
Lab Sample ID: J6D0481-10
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:10

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2053

Analytical Testing Parameters

Client Sample ID: P.S. 8
Lab Sample ID: J6D0481-11
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:12

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2056

Analytical Testing Parameters

Client Sample ID: P.S. 9
Lab Sample ID: J6D0481-12
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:13

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00248, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2100



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 10
Lab Sample ID: J6D0481-13
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:14

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2103

Analytical Testing Parameters

Client Sample ID: P.S. 11
Lab Sample ID: J6D0481-14
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:15

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2107

Analytical Testing Parameters

Client Sample ID: P.S. 12
Lab Sample ID: J6D0481-15
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:16

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2110



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 13
Lab Sample ID: J6D0481-16
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:17

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00107, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2114.

Analytical Testing Parameters

Client Sample ID: P.S. 15
Lab Sample ID: J6D0481-17
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:18

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2117.

Analytical Testing Parameters

Client Sample ID: P.S. 17
Lab Sample ID: J6D0481-18
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:20

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2128.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 18
Lab Sample ID: J6D0481-19
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:21

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2131

Analytical Testing Parameters

Client Sample ID: P.S. 19
Lab Sample ID: J6D0481-20
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:22

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2135

Analytical Testing Parameters

Client Sample ID: P.S. 20
Lab Sample ID: J6D0481-21
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:23

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2138



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 21
Lab Sample ID: J6D0481-22
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:24

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2142

Analytical Testing Parameters

Client Sample ID: P.S. 22
Lab Sample ID: J6D0481-23
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:25

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2145

Analytical Testing Parameters

Client Sample ID: P.S. 23
Lab Sample ID: J6D0481-24
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:26

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1539, 04/18/16 2149





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 24
Lab Sample ID: J6D0481-25
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:27

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2152

Analytical Testing Parameters

Client Sample ID: P.S. 25
Lab Sample ID: J6D0481-26
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:28

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2214

Analytical Testing Parameters

Client Sample ID: P.S. 26
Lab Sample ID: J6D0481-27
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:29

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2217



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 27
Lab Sample ID: J6D0481-28
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:30

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00143, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2221

Analytical Testing Parameters

Client Sample ID: P.S. 29
Lab Sample ID: J6D0481-29
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:32

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2224

Analytical Testing Parameters

Client Sample ID: P.S. 31
Lab Sample ID: J6D0481-30
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:34

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00106, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2228



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 32
Lab Sample ID: J6D0481-31
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:35

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2231

Analytical Testing Parameters

Client Sample ID: P.S. 33
Lab Sample ID: J6D0481-32
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:37

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2235

Analytical Testing Parameters

Client Sample ID: P.S. 34
Lab Sample ID: J6D0481-33
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:39

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00122, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2238



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 35
Lab Sample ID: J6D0481-34
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:40

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2242

Analytical Testing Parameters

Client Sample ID: P.S. 36
Lab Sample ID: J6D0481-35
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:42

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2252

Analytical Testing Parameters

Client Sample ID: P.S. 37
Lab Sample ID: J6D0481-36
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:44

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2256



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 38
Lab Sample ID: J6D0481-37
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:45

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2259

Analytical Testing Parameters

Client Sample ID: P.S. 40
Lab Sample ID: J6D0481-38
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:47

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2303

Analytical Testing Parameters

Client Sample ID: P.S. 43
Lab Sample ID: J6D0481-39
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:50

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00110, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2307



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: P.S. 28
Lab Sample ID: J6D0481-40
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:52

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2310

Analytical Testing Parameters

Client Sample ID: P.S. 39
Lab Sample ID: J6D0481-41
Sample Type: Grab

Collected By: Client
Collection Date: 04/07/16
Collection Time: 06:54

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2314

Analytical Testing Parameters

Client Sample ID: M.S. 1
Lab Sample ID: J6D0481-42
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:30

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00112, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2317



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: M.S. 2
Lab Sample ID: J6D0481-43
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:31

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2321

Analytical Testing Parameters

Client Sample ID: M.S. 3
Lab Sample ID: J6D0481-44
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:32

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1559, 04/18/16 2324

Analytical Testing Parameters

Client Sample ID: M.S. 10
Lab Sample ID: J6D0481-45
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:34

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00212, 0.00100, mg/L, 04/18/16 1623, 04/18/16 2335



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: M.S. 4
Lab Sample ID: J6D0481-46
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:35

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1623, 04/18/16 2349.

Analytical Testing Parameters

Client Sample ID: M.S. 5
Lab Sample ID: J6D0481-47
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:36

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1623, 04/18/16 2352.

Analytical Testing Parameters

Client Sample ID: M.S. 6
Lab Sample ID: J6D0481-48
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:37

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00181, 0.00100, mg/L, 04/18/16 1623, 04/18/16 2356.





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: M.S. 7
Lab Sample ID: J6D0481-49
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:38

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00360, 0.00100, mg/L, 04/18/16 1623, 04/19/16 0000

Analytical Testing Parameters

Client Sample ID: M.S. 8
Lab Sample ID: J6D0481-50
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:39

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1623, 04/19/16 0003

Analytical Testing Parameters

Client Sample ID: M.S. 9
Lab Sample ID: J6D0481-51
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:42

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00185, 0.00100, mg/L, 04/18/16 1623, 04/19/16 0007



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Analytical Testing Parameters

Client Sample ID: M.S. 11
Lab Sample ID: J6D0481-52
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:44

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00215, 0.00100, mg/L, 04/18/16 1623, 04/19/16 0017

Analytical Testing Parameters

Client Sample ID: P.S. 16
Lab Sample ID: J6D0481-53
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:45

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1623, 04/19/16 0021

Analytical Testing Parameters

Client Sample ID: H.S. 42
Lab Sample ID: J6D0481-54
Sample Type: Grab

Collected By: Client
Collection Date: 04/08/16
Collection Time: 06:15

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 04/18/16 1623, 04/19/16 0024

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
PQL: Practical Quantitation Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0481

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield  
Division Manager  
04/20/2016 17:23

**Go Green:** Contact Michael Fifield to set up email reporting and invoicing options.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.*

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Oxford Academy & Central School District						Ice: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
Address: 50 South Washington Street						Cooler: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
Contact: Oxford, NY 13830						Sample Temp: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Contact: Mark Hodge						Cooler Seal: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Phone: 607-843-2025 Xr: 1156						Pickup: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Project: DW Lead Testing						Dropoff: C <input type="checkbox"/> W <input type="checkbox"/>	
Quote ID: Lead Testing		PO#:				Accepted? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
Rush TAT Bus. Days: <2 2-5 5-7 7-10		Date Req.:				Container Material	
Carbon Copy: Yes						Container Size(in Mi)	
Email Results: Yes						Preservative	
Fax Results: Yes						Comments/Field Data	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Matrix	Type	Plastic	250 ml	HNO3
1 H.S. 1	4-7-16	6:00		Gr/DW	1		
2 H.S. 2		6:01					
3 H.S. 3		6:02					
4 H.S. 4		6:03					
5 H.S. 5		6:04					
6 H.S. 44		6:05					
7 H.S. 16		6:06					
8 H.S. 6		6:07					
9 H.S. 41		6:09					
10 P.S. 7		6:10					
11 P.S. 8		6:12					
12 P.S. 9		6:13					
13 P.S. 10		6:14					
14 P.S. 11		6:15					
15 P.S. 13		6:16					



J6D0481

Print Name and Company		Date/Time	Comments
Sampled: <i>Christopher's Food</i>			
Received: <i>Christine Rhodes MLI</i>			
Sampled: <i>Christine Rhodes MLI</i>			
Received: <i>Christine Rhodes MLI</i>			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Oxford Academy & Central School District						Ice: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
Address: 50 South Washington Street						Cooler: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
Contact: Mark Hodge						Sample Temp: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Phone: 607-843-2025 Xt: 1156						Cooler Seal: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Project: DW Lead Testing						Pickup: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Quote ID: Lead Testing		PO#:				Dropoff: C <input type="checkbox"/> W <input type="checkbox"/>	
Rush TAT Bus. Days: <2 2-5 5-7 7-10		Date Req.:				Accepted? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
Carbon Copy: Yes						Container Material: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Email Results: Yes						Container Size (in Mi): YES <input type="checkbox"/> NO <input type="checkbox"/>	
Fax Results: Yes						Preservative: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Matrix	Type			
1 P.S. 13	4-7-16	6:19	Gr/DW		1		
2 P.S. 14							
3 P.S. 15		6:19					
4 P.S. 17		6:20					
5 P.S. 18		6:21					
6 P.S. 19		6:22					
7 P.S. 20		6:23					
8 P.S. 21		6:24					
9 P.S. 22		6:25					
10 P.S. 23		6:26					
11 P.S. 24		6:27					
12 P.S. 25		6:28					
13 P.S. 26		6:29					
14 P.S. 27		6:30					
15 P.S. 29		6:32					



J6D0481

Print Name and Company		Date/Time	Comments
Christine Rhoads MLI Creative Coolers		4/8/16 9:53	
Sampled:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)					
Name: Oxford Academy & Central School District						Ice: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>					
Address: 50 South Washington Street Oxford, NY 13830						Cooler: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>					
Contact: Mark Hodge						Sample Temp: YES <input type="checkbox"/> NO <input type="checkbox"/>					
Phone: 607-843-2025 Xr: 1156						Cooler Seal: YES <input type="checkbox"/> NO <input type="checkbox"/>					
Project: DW Lead Testing						Pickup: YES <input type="checkbox"/> NO <input type="checkbox"/>					
Quote ID: Lead Testing PO#:						Dropoff: C <input type="checkbox"/> W <input type="checkbox"/>					
Rush TAT Bus. Days: <2 2-5 5-7 7-10		Date Req.:				Accepted? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>					
Carbon Copy: Yes						Container Material					
Email Results: Yes						Container Size(in Mi)					
Fax Results: Yes						Preservative					
<b>Sample Information</b>				Number of Containers for Analysis Requested				Comments/Field Data			
Description/Location	Date	Time	Matrix	Type							
1 P.S. 30	4-7-16	6:34	Gr/DW		1						
2 P.S. 31		6:35									
3 P.S. 32		6:37									
4 P.S. 33		6:39									
5 P.S. 34		6:40									
6 P.S. 35		6:42									
7 P.S. 36		6:44									
8 P.S. 37		6:45									
9 P.S. 38		6:47									
10 P.S. 40		6:50									
11 P.S. 43		6:52									
12 P.S. 28		6:54									
13 P.S. 39		6:54									
14 M.S. I	7-8-16	6:30									
15 M.S. 2		6:31									



J6D0481

Print Name and Company: *Christopher I. Ford*  
 Date/Time: *4-18-16 9:53*  
 Comments: *Justin Hodge MLE Andrew Hodge*

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:	
Name: Oxford Academy & Central School District			
Address: 50 South Washington Street Oxford, NY 13830			
Contact: Mark Hodge			
Phone: 607-843-2025 Xt: 1156			
Project: DW Lead Testing			
Quote ID: Lead Testing	PO#:		
Rush TAT Bus. Days: <2 2-5 5-7 7-10	Date Req.:		
Carbon Copy: Yes			
Email Results: Yes			
Fax Results: Yes			
<b>Sample Information</b>			
Description/Location	Date	Time	Matrix Type
1 M.S.-3	4-8-16	6:32	Gr/DW
2 M.S.-10		6:34	
3 M.S.-4		6:33	
4 M.S.-5		6:36	
5 M.S.-6		6:37	
6 M.S.-7		6:38	
7 M.S.-8		6:39	
8 M.S.-9		6:40	
9 M.S.-11		6:44	
10		7:00	
11			
12			
13			
14			
15			

Analysis Requested		Receiving Info (Lab Use Only)	
Total Lead (DW) (EPA 200.8)		Ice:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Plastic		Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
250 ml		Sample Temp:	
HNO3		Cooler Seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>
		Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>
		Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>
		Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
		Container Material	
		Container Size (in MI)	
		Preservative	
		Comments/Field Data	



J6D0481

Print Name and Company: *Christopher I. Ford*  
 Date/Time: *4/8/16 9:53*  
 Comments: *Christian Chodes MLI*  
 Sampled: *Christian Chodes*  
 Received: *Christian Chodes*  
 Received: *Christian Chodes*

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Oxford Academy & Central School District		Total Lead (DW) (EPA 200.8)				Ice: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
Address: 50 South Washington Street Oxford, NY 13830		Matrix				Cooler: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
Contact: Mark Hodge		Type				Sample Temp:	
Phone: 607-843-2025 Xt: 1156		Date				Cooler Seal: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Project: DW Lead Testing		Time				Pickup: YES <input type="checkbox"/> NO <input type="checkbox"/>	
Quote ID: Lead Testing		Gr/DW				Dropoff: C <input type="checkbox"/> W <input type="checkbox"/>	
Rush TAT Bus. Days: <2 2-5 5-7 7-10		Date				Accepted? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
Carbon Copy: Yes		Date				Container Material	
Email Results: Yes		Time				Container Size(in Mil)	
Fax Results: Yes		Date				Preservative	
PO#: _____		Date				Comments/Field Data	
Date Req.: _____		Time					
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Matrix	Type	1	2	3
1 H.S. 1	4-7-16	6:00		Gr/DW	1		
2 H.S. 2		6:01					
3 H.S. 3		6:02					
4 H.S. 4		6:03					
5 H.S. 5		6:04					
6 H.S. 44		6:05					
7 H.S. 16		6:06					
8 H.S. 6		6:07					
9 H.S. 41		6:09					
10 P.S. 7		6:10					
11 P.S. 8		6:12					
12 P.S. 9		6:13					
13 P.S. 10		6:14					
14 P.S. 11		6:15					
15 P.S. 13		6:16					



J6D0481

Print Name and Company: \_\_\_\_\_  
 Date/Time: \_\_\_\_\_  
 Comments: \_\_\_\_\_  
 Sampled: \_\_\_\_\_  
 Received: Christophersford  
 Received: Christine Rhoads MLI  
 Received: Christine Rhoads 4/8/16 953  
 Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.



3821 Buck Drive  
 Cortland NY 13045  
 Phone: (607) 753-3403 Fax: (607) 753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc. **CHAIN OF CUSTODY**

Samples must be returned on ice  
 MNY Workorder #

Client Information			Billing/Invoice:		Analysis Requested			Receiving Info (Lab Use Only)	
Name:	Oxford Academy & Central School District							Ice:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Address:	50 South Washington Street Oxford, NY 13830							Cooler:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Contact:	Mark Hodge							Sample Temp:	
Phone:	607-843-2025 Xt: 1156							Cooler Seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Project:	DW Lead Testing							Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Quote ID:	Lead Testing	PO#:						Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:						Accepted?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Carbon Copy:	Yes							Container Material:	
Email Results:	Yes							Container Size (in Ml)	
Fax Results:	Yes							Preservative	
Sample Information				Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Matrix	Type					
1 P.S. 13	4-7-16	6:17	Gr/DW		1				
2 P.S. 14									
3 P.S. 15		6:19							
4 P.S. 17		6:20							
5 P.S. 18		6:21							
6 P.S. 19		6:22							
7 P.S. 20		6:23							
8 P.S. 21		6:24							
9 P.S. 22		6:25							
10 P.S. 23		6:26							
11 P.S. 24		6:27							
12 P.S. 25		6:28							
13 P.S. 26		6:29							
14 P.S. 27		6:30							
15 P.S. 29		6:32							




J6D0481

Print Name and Company: *Christine Rhodes MCF Custody Checker*  
 Date/Time: 4/8/16 9:53  
 Sampled: *Christine Rhodes*  
 Received: *Christine Rhodes*  
 Received: *Christine Rhodes*

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)					
Name:	Oxford Academy & Central School District					Ice:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>				
Address:	50 South Washington Street Oxford, NY 13830					Cooler:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>				
Contact:	Mark Hodge					Sample Temp:	YES <input type="checkbox"/> NO <input type="checkbox"/>				
Phone:	607-843-2025 Xt: 1156					Cooler Seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>				
Project:	DW Lead Testing					Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>				
Quote ID:	Lead Testing	PO#:				Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>				
Rush TAT Bus. Days: <2 2-5 5-7 7-10		Date Req.:				Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				
Carbon Copy: Yes						Container Material					
Email Results: Yes						Container Size(in MI)					
Fax Results: Yes						Preservative					
Sample Information				Number of Containers for Analysis Requested				Comments/Field Data			
Description/Location	Date	Time	Matrix	Type							
1 P.S. 30				Gr/DW	1						
2 P.S. 31	4-7-16	6:34									
3 P.S. 32		6:35									
4 P.S. 33		6:37									
5 P.S. 34		6:39									
6 P.S. 35		6:40									
7 P.S. 36		6:42									
8 P.S. 37		6:44									
9 P.S. 38		6:45									
10 P.S. 40		6:47									
11 P.S. 43		6:50									
12 P.S. 28		6:52									
13 P.S. 39		6:54									
14 M.S. 1	7-8-16	6:30									
15 M.S. 2		6:31									



J6D0481

Print Name and Company: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments: \_\_\_\_\_

Received: *Christy E. Egan*

Received: *Christy Egan*

Received: *Andrew Shodor 418/16 953*

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

Samples must be returned on ice  
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Oxford Academy & Central School District						Ice: YES NO	
Address: 50 South Washington Street						Cooler: YES NO	
Contact: Oxford, NY 13830						Sample Temp: YES NO	
Contact: Mark Hodge						Cooler Seal: YES NO	
Phone: 607-843-2025 Xt: 1156						Pickup: YES NO	
Project: DW Lead Testing						Dropoff: C W	
Quote ID: Lead Testing		PO#:				Accepted? YES NO	
Rush TAT Bus. Days: <2 2-5 5-7 7-10		Date Req.:				Container Material	
Carbon Copy: Yes						Container Size(in Mi)	
Email Results: Yes						Preservative	
Fax Results: Yes						Comments/Field Data	
<b>Sample Information</b>							
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested		
1 M.S. 3	4-8-16	6:32		Gr/DW	1		
2 M.S. 10		6:34					
3 M.S. 4		6:35					
4 M.S. 5		6:36					
5 M.S. 6		6:37					
6 M.S. 7		6:38					
7 M.S. 8		6:39					
8 M.S. 9		6:42					
9 M.S. 11		6:44					
10 P.S. 16		7:00		6:45			
11 H.S. 42				6:15			
12							
13							
14							
15							



J6D0481

Print Name and Company		Date/Time	Comments
sampled: <i>Christopher I. Ford</i> received: <i>Christina Chodes MLI</i> received: <i>Christina Chodes MLI</i>		4/8/16 9:53	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.