



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Oxford Academy and Central School District

Project Name: Oxford Academy School

Mark Hodge
50 S Washington AVE
Oxford, NY 13830

Project / PO Number: N/A
Received: 12/17/2024
Reported: 12/31/2024

Analytical Testing Parameters

Client Sample ID:	Room 112	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:32
Lab Sample ID:	J4L0744-01		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1414	JDF

Client Sample ID:	Room 110	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:33
Lab Sample ID:	J4L0744-02		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1419	JDF

Client Sample ID:	Room 108	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:34
Lab Sample ID:	J4L0744-03		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1420	JDF

Client Sample ID:	Room 106	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:34
Lab Sample ID:	J4L0744-04		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1422	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Client Sample ID: Sink Across From 106

Sample Matrix: Drinking Water

Lab Sample ID: J4L0744-05

Collected By: Jared Gorman

Collection Date: 12/17/2024 6:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1423	JDF

Client Sample ID: Room 104

Sample Matrix: Drinking Water

Lab Sample ID: J4L0744-06

Collected By: Jared Gorman

Collection Date: 12/17/2024 6:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1425	JDF

Client Sample ID: Sink Across From 104

Sample Matrix: Drinking Water

Lab Sample ID: J4L0744-07

Collected By: Jared Gorman

Collection Date: 12/17/2024 6:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0072	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1429	JDF

Client Sample ID: Room 102

Sample Matrix: Drinking Water

Lab Sample ID: J4L0744-08

Collected By: Jared Gorman

Collection Date: 12/17/2024 6:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1431	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Client Sample ID:	Room 202	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:41
Lab Sample ID:	J4L0744-09		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1432	JDF

Client Sample ID:	Room 204	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:41
Lab Sample ID:	J4L0744-10		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1440	JDF

Client Sample ID:	Room 206	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:42
Lab Sample ID:	J4L0744-11		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1442	JDF

Client Sample ID:	Room 208	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:43
Lab Sample ID:	J4L0744-12		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1444	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Client Sample ID:	Room 210	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:44
Lab Sample ID:	J4L0744-13		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1446	JDF

Client Sample ID:	Room 214	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:45
Lab Sample ID:	J4L0744-14		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1448	JDF

Client Sample ID:	Room 216	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:46
Lab Sample ID:	J4L0744-15		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1449	JDF

Client Sample ID:	Room 218	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:46
Lab Sample ID:	J4L0744-16		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1453	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Client Sample ID:	Room 220	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:47
Lab Sample ID:	J4L0744-17		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1455	JDF

Client Sample ID:	Sink By Steam Room	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:48
Lab Sample ID:	J4L0744-18		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1457	JDF

Client Sample ID:	Room 224 Single Sink	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:48
Lab Sample ID:	J4L0744-19		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1458	JDF

Client Sample ID:	Room 224 Double Sink	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:49
Lab Sample ID:	J4L0744-20		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.005 AL	0.0010	mg/L		12/26/24 1254	12/26/24 1500	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Client Sample ID:	Room 228	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:50
Lab Sample ID:	J4L0744-21		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1241	JDF

Client Sample ID:	Room 230	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:51
Lab Sample ID:	J4L0744-22		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1243	JDF

Client Sample ID:	Room 232	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:52
Lab Sample ID:	J4L0744-23		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1244	JDF

Client Sample ID:	Room 234	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:53
Lab Sample ID:	J4L0744-24		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1249	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Client Sample ID:	Room 236	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:53
Lab Sample ID:	J4L0744-25		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1250	JDF

Client Sample ID:	Room 240	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:54
Lab Sample ID:	J4L0744-26		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1252	JDF

Client Sample ID:	Room 256	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:55
Lab Sample ID:	J4L0744-27		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1253	JDF

Client Sample ID:	Room 254	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:56
Lab Sample ID:	J4L0744-28		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1258	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Client Sample ID:	Room 252	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:57
Lab Sample ID:	J4L0744-29		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1259	JDF

Client Sample ID:	Room 250	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:58
Lab Sample ID:	J4L0744-30		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1301	JDF

Client Sample ID:	MPR Kitchen Sink	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 6:59
Lab Sample ID:	J4L0744-31		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1302	JDF

Client Sample ID:	Staff Bathroom Left	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 7:00
Lab Sample ID:	J4L0744-32		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1307	JDF



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J4L0744

Client Sample ID:	Staff Bathroom Right	Collected By:	Jared Gorman
Sample Matrix:	Drinking Water	Collection Date:	12/17/2024 7:01
Lab Sample ID:	J4L0744-33		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		12/26/24 1215	12/26/24 1308	JDF

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level
mg/L: Milligrams per Liter
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 12/31/2024 08:56

CHAIN OF CUSTODY RECORD

2368 Elmira St., Suite C Cortland, NY 13045 607.753.3403

420 Route 316 Hwy Pittston, PA 16640 670.348.0716

4350 Linglestown Rd. Harrisburg, PA 17112 717.651.0700

Lab Report Address: Client Name: OXFORD ACADEMY SCHOOLS

Address: 50 SOUTH WASHINGTON ST. Address: R.O. BOX 192

City, State, Zip: OXFORD, N.Y. 13830 City, State, Zip: OXFORD, N.Y. 13830

Contact: MARK HODGE Contact: HOPE CRAWFORD

Telephone No.: (607) 843-2025 EXT. 1156 Telephone No.: (607) 843-2025 EXT. 4042

Send Report via: [] Mail [] Fax [] e-mail (address) Send Invoice via: [] Mail [] Fax [] e-mail (address)

Project: Location: Water Dist. PO No.: Compliance Monitoring? [] Yes [] No

Sampled by (PRINT): SARA GARMAN Sampler Signature: [Signature] Sampler Phone No.: (607) 843-2025 EXT. 3114

** Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

LEAD (Pb)

Matrix

No. of Containers

Time Collected

Date Collected

Lab ID

Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)

11 014312 RM 206 12-17-24 6:42

12 019236 RM 208 6:43

13 013897 RM 210 6:44

14 019242 RM 214 6:45

15 019157 RM 216 6:46

16 013764 RM 218 6:46

17 013760 RM 220 6:47

18 000028 SINK BY STEAM RM 6:48

19 000005 RM 224 SINGLE SINK 6:48

20 019243 RM 224 DOUBLE SINK 6:49

Possible Hazard Identification [] Hazardous [] Not Hazardous [] Radioactive []


Comments

PLEASE SUBMIT PAYMENT WITH SAMPLES.

PLEASE RETURN SAMPLES ON ICE.

PLEASE BE SURE TO FILL THE CONTAINER(S) UP TO THE SHOULDER

*HN03 ADDED TO EACH SAMPLE - J432022 - RLF 12/17/24



Received By (signature) Daniel Fasho Date/Time 12/17/24 09:40

Received By (signature) Date/Time PAGE 02 OF 04

CHAIN OF CUSTODY RECORD

Number ALF 12/17/24

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 Level 2 Level 3 Level 4 Level 5

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No

Agency/Program

Sampler Phone No.:

(607) 843-2025 ext. 3114

Sample Types: Solid (S), Liquid (L), Wipe (W), Drinking Water (DW), Surface Water (SW), Waste Water (WW), Other (specify)

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

LEAD (Pb)

RUF 12-17-24

Preservative Types

Grab / Comp

Matrix

No. of Containers

Time Collected

Date Collected

Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink, etc.)

Lab ID

013762 MPE KITCHEN SINK

013789 STAFF BATHROOM LEFT

019168 STAFF BATHROOM RIGHT

31

32

33

Possible Hazard Identification

Committee

Hazardous Non-Hazardous

Radioactive

Sample Disposition

Dispose as appropriate Return Archive

PLEASE SUBMIT PAYMENT WITH SAMPLES.

PLEASE RETURN SAMPLES ON ICE.

PLEASE BE SURE TO FILL THE CONTAINER(S) UP TO THE SHOULDER

* HN03 ADDED TO EACH SAMPLE - J432022 - RLF 12/17/24

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

* HN03 ADDED TO EACH SAMPLE - J432022 - RLF 12/17/24

PAGE 04 OF 04

Oxford Academy and Central School District
PM: Shannon Weeks



J 4 L 0 7 4 4

Lab Report Address

Client Name: OXFORD ACADEMY SCHOOLS

Address: 50 SOUTH WASHINGTON ST.

City, State, Zip: OXFORD, N.Y. 13830

Contact: MARK HODGE

Telephone No.: (607) 843-2025 ext. 1156

Send Report via: Mail Fax e-mail (address)

Invoice Address

Client Name: OXFORD ACADEMY SCHOOLS

Address: PO BOX 192

City, State, Zip: OXFORD, N.Y. 13830

Contact: HOPE CRAWFORD

Telephone No.: (607) 843-2025 ext. 4042

Send Invoice via: Mail Fax e-mail (address)

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 Level 5

Send Invoice via: Mail Fax e-mail (address)

Location:

Water Dist.

PO No.:

Sampler Signature: Jared Gorman

Sampler Phone No.:

(607) 843-2025 ext. 3114

Sample Types: Solid (S), Liquid (L), Wipe (W), Drinking Water (DW), Surface Water (SW), Waste Water (WW), Other (specify)

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

LEAD (Pb)

RUF 12-17-24

Preservative Types

Grab / Comp

Matrix

No. of Containers

Time Collected

Date Collected

Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink, etc.)

Lab ID

013762 MPE KITCHEN SINK

013789 STAFF BATHROOM LEFT

019168 STAFF BATHROOM RIGHT

31

32

33